

**Fire Hydrant Information.**

**NFPA 291, Annex I Fire Hydrant Locations and Distribution.**

**\*State of Arkansas Fire Safety Code; Section 508, 508.5.1 through 508.5.6.**

**ISO (Insurance Services Office); Fire Protection Rating Schedule, Item 600 to 640.**

**\*\*When ISO develops a single Public Protection Classification (PPCTM) for a community, all of the community's properties receive that classification. In many communities, ISO develops a split classification (for example, 5/9). Generally, the first class, (Class 5 in the example) applies to properties within five road miles of a fire station and within 1,000 feet of a fire hydrant. The second class (Class 9 in the example) applies to properties within five road miles of a fire station but beyond 1,000 feet of a hydrant. ISO generally assigns Class 10 to properties beyond five road miles.**