

MATT SILAS ARCHITECT

202 West Washington
P.O. Box 1702
Jonesboro, Arkansas 72403
Tel.(870) 268-0500
Fax. (870) 268-0501

ADDENDUM NUMBER 4

ISSUE DATE: SEPTEMBER 10, 2003

**PROJECT: ALLEN PARK TENNIS COURTS AND SIDEWALK IMPROVEMENTS -
JONESBORO, ARKANSAS.**

PROJECT NUMBER: 020304

OWNER: CITY OF JONESBORO

ARCHITECT: MATT SILAS ARCHITECT

TO: PROSPECTIVE BIDDERS

Please review items noted in this addendum. This addendum forms a part of the contract documents and modifies the bidding documents as indicated below. Acknowledge receipt of this addendum in the space provided in the bid form. Failure to do so may disqualify the bidder.

SPECIFICATIONS

Documents 0 - Introductory Information, Bidding requirements, and Contract Requirements

Section 00410 - Bid Form

1.09 Addenda - Paragraph A.

1. Add a line item for Addendum No. 3 and Addendum No. 4 on the Bid Form with date received.

ADDENDA

Refer to Addendum No. 3

Grate and Drainage Channel Paragraph.

The last sentence should read as follows:

The grate channel on the East side of the court area and the drainage structures North of the court area will **NOT** be part of the Contractor's Bid.

DRAWINGS

Electrical

1. The lighting system in Alternate No. One, as modified previously by addenda, is based on products manufactured by Hubbell Lighting. This system will meet the initial and maintained light levels specified in previous addenda and consists of (5) 1000 watt light fixtures per pole (ten for the two double fixture rack poles). The power feeders for this system have been modified by addenda. Lighting systems by other manufacturers that will provide equal service and meet the light level requirements may be substituted. For other systems proposed as substitutions, it is the contractors responsibility to verify the number of fixtures, configuration, mounting height, aiming points and any other applicable factors which are necessary to provide the light levels required. Should a system proposed as a substitute have different power requirements, it is the contractors responsibility to include in his bid price the cost of any changes required in the power supply system, including but not necessarily limited to, main switchgear circuit breaker, feeder wiring and conduit to Panel 'A', size and configuration of Panel 'A', circuit breakers, feeder wiring and conduit to the light fixtures, photocell, timer and lighting contactor.

End of Addendum No. 4