

## Otis Spriggs

---

**From:** Craig Davenport  
**Sent:** Tuesday, April 14, 2015 9:19 AM  
**To:** Otis Spriggs  
**Subject:** Subdivisions

Otis,

I agree with the State Fire marshal's office on this. The new design must include a distant second exit, otherwise it is restricted to 30 homes or all homes must be sprinkled with a 13D sprinkler system. It should be noted however that the second access need not be a connecting street. A 20 foot wide easement with an all weather surface used only for FD/EMS access is acceptable. I hope this helps. If you have any further questions don't hesitate to contact me.

**Craig Davenport**  
**Chief Fire Marshal**  
**Jonesboro Fire Department**  
**(870) 932-2428**