

DEPARTMENT OF INSPECTION AND CODE ENFORCEMENT

RESIDENTIAL BUILDING INSPECTION REPORT

DATE OF INSPECTION:	JUNE 4, 2024 CASE NUMBER: 231413	
PROPERTY ADDRESS:	300 PINE ST.	
PROPERTY OWNER:	KEVIN L & TONYA LYLES	

The residence is on a pier foundation. The home burned in April 9, 2023. Since that time no repair work has occurred. The entire carport has fallen off the home and the south half of the roof is caving in from the fire damage. The falling area of roof is pulling on the rest of the roof. The home is too dangerous to thoroughly inspect the interior. All rafters were damaged by the fire. All windows and doors are boarded and/or broken. There is extensive smoke and fire damage to the soffit. The entire electrical system must be replaced, brought up to current code, and pass inspection. The entire plumbing system must be replaced, brought up to current code, and pass inspection.

CURRENTLY THE HOME IS A HAZARD TO THE HEALTH, WELFARE, AND SAFETY OF THE PUBLIC. THE HOME SHOULD BE RAZED IMMEDIATELY TO ENSURE THE SAFETY OF LOCAL CHILDREN AND OTHER CITIZENS, NOT TO MENTION THE BLIGHT TO THE COMMUNITY.

PROPERTY WAS NOT SECURED AT THE TIME OF INSPECTION.

In my opinion, this structure		Is	XX	Is not	Suitable for human habitation.	
In my opinion, this structure		Is	XX	Is not	Physically feasible for rehabilitation.	
In my opinion, this structure		Is	XX	Is not	Economically feasible for rehabilitation.	
In my opinion, this structure	XX	Is		Is not	A public safety hazard and should be condemned immediately.	
EMERGENCY ACTION IS WARRANTED: YES NO XX						

Tim Renshaw, Chief Building Inspector	David Cooley, Code Enforcement		
Lenston	Toly		

Municipal Building, 300 South Church Jonesboro, AR/ Phone 870-336-7194/Fax 870-336-1358