

Michael Boggs

From: Carmack, Rick L. <Rick.Carmack@ardot.gov>
Sent: Monday, June 8, 2020 4:27 PM
To: Michael Boggs
Cc: Walter, Alan K.
Subject: RE: 3701 E Johnson Ave

Michael,

Please allow this email to serve as notification that ARDOT will not allow a sidewalk to be constructed within the State right of way along the travel lane based on the open shoulder design of Hwy 49 at the proposed location (3701 E. Johnson Ave.) Also placement at the back of the r/w would not be allowed due to the drastic drop in grade towards the northern edge of the property as well as blocking drainage at the storm drain inlet just west of the existing driveway entrance.

Respectfully
Rick Carmack
District Permit Officer



Arkansas Department of Transportation

Rick.Carmack@ArDot.gov
District 10 Permit Officer
2510 Hwy 412
P.O. Box 98
Paragould, AR 72451
870-239-9511 Office
870-476-1922 Mobile
870-236-1156 Fax
