



JONESBORO FIRE DEPARTMENT

3215 EAST JOHNSON
JONESBORO, AR. 72401

870-932-2428

Protecting Lives and Property since 1899

Pre - Annexation Questionnaire

1. Location.(address/directions) 5202 Woodsprings Road South
on 49 Hwy To 226, Turn ~~West~~ on 226 1 mile, Property
on Left. North
2. Size of Area to be annexed. (acres, sq. miles, etc.) 3.23 Acres
3. **Distance from the nearest City of Jonesboro Fire Station to property and to the further most edge of property, away from the City of Jonesboro Fire Station.
 - Road Miles including 1/10th 4.3 mile
 - Feet (if applicable) _____
4. Water Main size; 6"
5. Parcel,
 - ** Nearest 2 Fire Hydrants;
 - (1.) 30' North East of SE corner of Property
 - (2.) 0.3 mile North on Hwy 226
6. Subdivision,
 - ** Number of Fire Hydrants; N/A
 - *Distance between Fire Hydrants; N/A
 - Number of Homes/Lots; 2
7. Greater than 1 Section of Land.
 - ** Number of Fire Hydrants; N/A
 - Number of Homes; N/A
 - Number of Commercial Structures; N/A
 - Number of Structures over 35 feet in height; N/A
8. Type of Roadways;

Asphalt, Gravel, etc. Asphalt

9. Bridges;

- Type None
- Capacity _____
- Width _____

10. Please attach map of proposed annexation.

Submitted by Joe Colman Date 1/28/2007

Contact Phone number 870-932-5900

Date _____
Fire Marshal

Comments _____

Date _____
Chief
Comments _____

Fire Hydrant Information.**NFPA 291, Annex I Fire Hydrant Locations and Distribution.*****State of Arkansas Fire Safety Code; Section 508, 508.5.1 through 508.5.6.****ISO (Insurance Services Office); Fire Protection Rating Schedule, Item 600 to 640.**

****When ISO develops a single Public Protection Classification (PPCTM) for a community, all of the community's properties receive that classification. In many communities, ISO develops a split classification (for example, 5/9). Generally, the first class, (Class 5 in the example) applies to properties within five road miles of a fire station and within 1,000 feet of a fire hydrant. The second class (Class 9 in the example) applies to properties within five road miles of a fire station but beyond 1,000 feet of a hydrant. ISO generally assigns Class 10 to properties beyond five road miles.**