

DEPARTMENT OF INSPECTION AND CODE ENFORCEMENT

RESIDENTIAL BUILDING INSPECTION REPORT

DATE OF INSPECTION:	September 4, 2025	CASE NUMBER: 255628	
PROPERTY ADDRESS:	233 S. Fisher St.	Parcel: 01-144181-44700	
PROPERTY OWNER:	Michael K. Kelly		

The residential building is a home on a pier foundation. The foundation is breaking down and causing the walls to bow out. The foundation must be repaired. All windows and doors are broken, missing, or boarded. All windows and doors must be repaired or replaced. Due to the walls bowing all load bearing walls must be closely inspected and any damaged studs must be replaced. There are many holes in the roof. Some of the rafters are rotten due to being exposed to the elements. Any rafters that are damaged must be replaced. The entire roof (underlay, singles, tar paper) must be replaced. There are holes in the soffit area around the home. Any damage to the soffit must be repaired. The interior of the home is completely full of trash ranging from approximately 6 inches deep to over 6 feet deep. I did not enter the home due to the condition of the structure and the amount of trash. The home is unsafe to enter for any reason. From the doorway I can see holes in the ceiling which appear to be from water damage due to the holes in the roof. The front porch is very soft and dangerous to walk on. Most of the decking has rotted off and the joists are breaking down.

CURRENTLY THE STRUCTURE IS A HAZARD TO THE HEALTH, WELFARE, AND SAFETY OF THE PUBLIC. THE STRUCTURE SHOULD BE RAZED IMMEDIATELY TO ENSURE THE SAFETY OF LOCAL CHILDREN AND OTHER CITIZENS, NOT TO MENTION THE BLIGHT TO THE COMMUNITY. PROPERTY WAS NOT SECURED AT THE TIME OF INSPECTION.

In my opinion, this structure		Is	XX	Is not	Suitable for human habitation.	
In my opinion, this structure		Is	XX	Is not	Physically feasible for rehabilitation.	
In my opinion, this structure		Is	XX	Is not	Economically feasible for rehabilitation.	
In my opinion, this structure	XX	Is		Is not	A public safety hazard and should be condemned immediately.	
EMERGENCY ACTION IS WARRANTED: YES NO XX						
Tim Renshaw, Chief Building Inspector					David Cooley, Code Enforcement	
Tim Lenson					Toly	

Municipal Building, 300 South Church Jonesboro, AR