


 Reply  Reply All  Forward



PLAT <do\_not\_reply@civicplus.com>

Tracy McGaha

## Update for request ID 3624: Plat Review

 If there are problems with how this message is displayed, click here to view it in a web browser.

### Recent Activity for Your Request

Comment added by *Margaret Norris* on January 14, 2020 4:51 PM

CWL will approve the plat, when the lot line between Lot 1C & Lot 1B is adjusted in a south west direction to allow for the fire sprinkler line & domestic tap to be on the lot they are serving.

### Plat Review

0000 E JOHNSON AVENUE  
JONESBORO, AR 72401

WOLF CREEK PLACE REVISED REPLAT - EASEMENTS ADDED

#3624

[Log In To  
Request Tracker](#)