



Legislation Details (With Text)

File #: ORD-89:1213 **Version:** 1 **Name:** Amend Code of Ordinances regarding the electrical code
Type: Ordinance **Status:** Passed
File created: 8/7/1989 **In control:** City Council
On agenda: **Final action:** 8/7/1989

Title: AN ORDINANCE TO AMEND CHAPTER 11.20, ELECTRICAL CODE, SECTIONS 11.20.02, 11.20.03, 11.20.06, 11.02.08, 11.2011, CHAPTER 11.24. LICENSING OF ELECTRICIANS, CONTRACTORS, ETC., SECTIONS 11.24.05, 11.24.06, 11.24.07, 11.24.08, 11.24.09, 11.24.10, 11.24.11, 11.24.12, AND 11.24.13, OF THE CODE OF ORDINANCES OF THE CITY OF JONESBORO, ARKANSAS, TO STREAMLINE THE ELECTRICAL CODE AND ITS ADMINISTRATION, AND FOR OTHER PURPOSES. (NOTE: THIS ORDINANCE WAS AMENDED BY ORD-90:1119 ON SEPTEMBER 17, 1990; ORD-97:1727 ON OCTOBER 6, 1997)

Sponsors:

Indexes: Code of Ordinances amendment

Code sections: Chapter 105 - Buildings & Building Regulations

Attachments:

Date	Ver.	Action By	Action	Result
8/7/1989	1	City Council	Passed	Pass
6/19/1989	1	City Council	Held at second reading	Pass
6/5/1989	1	City Council	Held at one reading	Pass

AN ORDINANCE TO AMEND CHAPTER 11.20, ELECTRICAL CODE, SECTIONS 11.20.02, 11.20.03, 11.20.06, 11.02.08, 11.2011, CHAPTER 11.24. LICENSING OF ELECTRICIANS, CONTRACTORS, ETC., SECTIONS 11.24.05, 11.24.06, 11.24.07, 11.24.08, 11.24.09, 11.24.10, 11.24.11, 11.24.12, AND 11.24.13, OF THE CODE OF ORDINANCES OF THE CITY OF JONESBORO, ARKANSAS, TO STREAMLINE THE ELECTRICAL CODE AND ITS ADMINISTRATION, AND FOR OTHER PURPOSES. **(NOTE: THIS ORDINANCE WAS AMENDED BY ORD-90:1119 ON SEPTEMBER 17, 1990; ORD-97:1727 ON OCTOBER 6, 1997)**

BE IT ORDAINED by the City Council of the City of Jonesboro, Arkansas:

SECTION 1: That Chapter 11.20, of the Code of Ordinances of the City of Jonesboro, Arkansas, is hereby amended as follow:

11.20.02 PERMIT - REQUIRED; APPLICATION; CONTENTS; ACTION BY ELECTRICAL INSPECTOR; ISSUANCE: Substitute “the City Electrical Inspector” for “its city collector” in the last line of Sub-section (A).

(D) Permits under this chapter may be issued only to persons duly licensed by the State of Arkansas under the Acts pertaining to the licensing of persons qualified thereunder, to engage in the making of electrical installations and repairs within the city.

11.20.03 SAME - TEMPORARY PERMIT REQUIREMENTS: Substitute “City Electrical Inspector who” for “city collector, the electrical inspector” in the third line.

11.20.08 INSPECTION FEES:

- (B) (1) Application issuance fee: Residential \$ 5.00
Commercial/Industrial buildings and apartments over two (2) units \$10.00
- (5) Change "Five Dollars (\$5.00)" to "Ten Dollars (\$10.00) in the 6th line
- (7) Unit Heaters: Each unit \$ 5.00
- (C) Change "Two Dollars (\$2.00)" to "Five Dollars (\$5.00)" in the first line.
- (D) All fees assessed under this section shall be collected by the City Planning and Inspection Department.

11.20.11 LOCAL EXCEPTIONS TO THE NATIONAL ELECTRICAL CODE: The following rules to govern local conditions shall be exceptions to the National Electrical Code:

- (1) All commercial buildings shall be wired in metal conduit. Metal conduit being defined as: (a) rigid conduit, (b) intermediate conduit, (c) E. M. T., electrical metallic tubing. Flexible metal conduit and flexible metal tubing may be used in accordance with the N.E.C. for flexibility for motors and from junction boxes to lights in lengths of not more than 6 feet.
- (2) No circuit shall be wired with less than No 12 copper wire.
- (3) Minimum size of aluminum wire that can be used is No. 6 strand.
- (4) PVC conduit shall not be installed where it is exposed to the outside elements. It can be used in underground installations as approved by the National Electrical Code. (Ordinance No. 1747, Section 2).
- (5) No meter shall be disconnected from line by anyone other than those securing permission to do so from the utility company supplying power.
- (6) No meter should be no less than 4 feet or more than 6 feet from ground level, or as approved by local utility.
- (7) All meters shall be outside of buildings and accessible at all times.
- (8) No residential service shall be less than No. 4-3 copper (100 amps) unless special permission is secured.
- (9) Service entrances shall clear above ground at least twelve (12) feet.
- (10) Service masts shall be not less than two (2") inch rigid conduits.
- (11) Ground rods not less than eight feet by ½ inch shall be used at service entrance.
- (12) No more than one (1) light opening shall be permitted on any one receptacle circuit or one (1) receptacle on a lighting circuit.
- (13) The National Electrical Code shall be followed in all cases where this Chapter does not apply.
- (14) All transformers used on gas filled signs or lamps shall be ninety-five (95%) percent power

corrected.

(15) All work shall be done in a workmanlike manner.

(16) Master switch or breaker shall be installed at the outer end of entrance at meter and entrance shall not be concealed.

(17) There shall be no more than (8) eight duplex receptacles or (8) eight lights per 20 amp circuit.

(18) The following rule shall apply to industrial and commercial wiring:

(A) No permit shall be issued until electrical contractor has furnished utility with plans and voltage and type of service and/or any service over 200 amp or any three phase service and utility has issued written approval.

SECTION 2: That Chapter 11.24, of the Code of Ordinances of the City of Jonesboro, Arkansas, is hereby amended as follows:

11.24.05 REVOCATION OF CERTIFICATE OF COMPETENCY:

Delete entire Section and renumber subsequent Sections.

11.24.06 PENALTY FOR VIOLATION: Substitute "City" for "board" in the third line and change to 11.24.05.

11.24.07 BOARD OF EXAMINERS OF ELECTRICIANS AND SUPERVISORS - CREATED; COMPOSITION; APPOINTMENT OF MEMBERS; TERMS OF OFFICE; VACANCIES. Delete entire Section and renumber subsequent Section.

11.24.08 SAME - ORGANIZATION; RECORDS TO BE KEPT; QUORUM. Delete entire Section and renumber subsequent Section.

11.24.09 SAME - ORGANIZATION; REMOVAL OF MEMBERS; AUTHORITY TO ADOPT RULES AND REGULATIONS FOR EXAMINATION OF APPLICANTS; TO BE FILED WITH CLERK; Delete entire Section and renumber subsequent Sections.

11.24.10 SAME - EXPENSES OF BOARD TO BE PAID BY CITY: Delete entire Section and renumber subsequent Section.

11.24.11 LICENSE REQUIRED; FEE. Renumber as 11.24.07.

11.24.12 BOARD OF REVIEW - CREATED; COMPOSITION; COMPENSATION; TERMS OF OFFICE. Delete entire Section.

11.24.13 SAME - POWERS AND DUTIE; QUORUM, etc. Delete entire Section

SECTION 3: If for any reason, any portion of this Ordinance is held to be invalid; such invalidity shall in no way effect the remaining portions thereof which are valid, but such valid portions shall remain in full force and effect.

SECTION 4: It is found and declared by the City Council that an emergency exists and this Ordinance being

necessary for the preservation of the public peace, health and safety, it shall take effect from and after its passage and approval.

PASSED AND ADOPTED this 7th day of August, 1989.